

FITNESS CERTIFICATE

To be filed by the Inspecting Officer (Asst. Engineer)
(Re: G.O. Ms. 20/70/ PWD Dt. 23 - 01 -1970)

1	Name of the Officer	<i>Abigith Ajikumar</i>	
2	Name of the School	<i>Saraswathy Vidyanikethan Secondary School Kudayathoor</i>	
3	Location with name of Education District/ Sub. District	<i>Kudayathoor, Thodupuzha, Arakkulam</i>	
4	Classification of Building as specified in column 4 of the application for fitness certificate and size.	<i>Permanent</i>	
5	Period for which the certificate is issued	<i>2024-2025</i>	
6	Nature of defects , if any	NO	<u>Permanent Building RCC Roofing</u> 1) GF 47.07 mx 8.26m x3.60m FF 47.07m x 8.26 m x 3.60 m SF 47.07 mx 8.26m x3.60 m (GI Sheet roof) SF of Permanent Building is not fit as per the order no EPA4/302/19 dtd 17/10/2019 Go.Order.No.114/2022/LSGD dtd 28.05.2022 Office room 25.20 mx 5.00m x 3.60(GI Sheet roof)
a)	Foundation and basement		
b)	Superstructure		
c)	Doors and Windows		
d)	Wood work wrought and put up		
e)	Roof		
f)	Flooring		
g)	Miscellaneous (Cracks, etc.)		
7	Any major defects noticed which will render the building unsafe in any manner	<i>No</i>	
8	Whether maintenance works have been done properly	<i>Yes</i>	
9	Whether the structure is sound or not for conducting classes	<i>Yes, The Structures are Sound under Normal wether Condition</i>	

Note : 1 The stability of the structure should be examined also with reference to location, altitude, intensity of wind, exposure of flood etc.

Note : 2 Any additional observations if deemed necessary for the certificate may be furnished separately with this certificate.

CERTIFICATE

*Certified that the school building was inspected by me on 09/05/2024 And found to be fit to
conduct classes, for the period 2024-2025 for the reasons stated above.*

Place: *Kudayathoor*
Date: *13/5/2024*



[Signature]
Assistant Engineer
LSGD (LID & EW) Section
Kudayathoor G.P.